



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11161
Inspection Number: 03748490

Building Inspection Report

Permit Information

Job Address: 300 QUAIL RIDGE CIR HIGHLANDS RANCH
Job Type: Electrical
Description: Service Change/Upgrade

Inspection Details

Inspection Date: 10/05/2022
Inspection Time: 10:16 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Matt Mazzara
Charge Reinspection Fee: No

Comments

- 1)secure all cables within 8" of TA garage panel
- 2)existing 3 wire range circuit must originate from service equipment 250.140