



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-02465
Inspection Number: 03748543

Building Inspection Report

Code Reviewed Under: 2018 IBC

Permit Information

Job Address: 10272A DEMOCRAT RD PARKER
Job Type: Building
Description: CM - Cell Site
Scope of Work: Alteration

Inspection Details

Inspection Date: 10/05/2022
Inspection Time: 1:41 PM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Approved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

3" PVC from transfer switch to east meter stack, 2" fiber stub to NE corner of fenced area