



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03755869

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 10/27/2022

Inspection Time: 12:15 PM

Inspection Type: Electric Service Equipment

Inspection Code: 23

Meter Release:

Provider: CORE

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

### Comments

1. Emergency disc sign missing per 230.85 at disc on house 2. 14AWG not permitted on 20A breaker in exterior panel 3. Secure HRs above panel within 12" 4. Missing screws at both panels.

Note-UFER in Basement directly behind exterior disc