



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03755870

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 10/27/2022

Inspection Time: 12:17 PM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

### Comments

1. Service not approved 2. A/C service GFCI inoperable 3. Closet, hall recepts require GFCI protection within 6' of sinks 4. Add recep outside of cab right of FP to cover wall space 5. Need additional recep on island 6. Cover horizontal cables in garage wall 7. Missing GFCI protected at RV garage 8. Blank plate missing at RV garage ceiling 9. Need permit for basement finish-currently has some walls framed and wired—install plates at boxes with devices and blank off all other boxes. Cover horizontal cables on both sides of unfinished walls 10. Bond screw in well disc loose