



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 05-05762  
Inspection Number: 02571319

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 9175 RED POPPY CT PARKER  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 08/24/2005  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Preliminary Defensible Space  
**Inspection Code:** 92  
**Outcome:** Approved  
**Inspected By:** Jill Welle  
**Charge Reinspection Fee:** No