



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-02559  
Inspection Number: 03759440

## Building Inspection Report

Code Reviewed Under: 2018 IBC

### Permit Information

**Job Address:** 565A FLINTWOOD RD FRANKTOWN  
**Job Type:** Building  
**Description:** CM - Cell Site  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 11/09/2022  
**Inspection Time:** 10:35 AM  
**Inspection Type:** Electric Trench  
**Inspection Code:** 16  
**Outcome:** Approved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Note-3" PVC service conduit transformer to transfer switch