



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03766198

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 12/02/2022

Inspection Time: 11:31 AM

Inspection Type: Construction Meter

Inspection Code: 10

Meter Release:

Provider: CORE

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

2020 NEC—1. EGC and neutral in feeder conduit required to be per 250.119 and 200.6 2. Feeder conduit EGC required to be sized to upstream OCPD 3. Retained Main required at temp with retainer and barriers 4. 240V recep requires GFCI protection 5. Replace damaged liquidtight