



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03776822

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 01/18/2023

Inspection Time: 10:32 AM

Inspection Type: Underground Plumbing

Inspection Code: 12

Outcome: Disapproved

Inspected By: Clayton Rodeback

Charge Reinspection Fee: No

### Comments

Pipes are covered in snow.