



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-00089
Inspection Number: 03781439

Building Inspection Report

Permit Information

Job Address: 9619 HUGGINS CT PARKER
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 02/06/2023
Inspection Time: 11:23 AM
Inspection Type: Final HVAC
Inspection Code: 39
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

1. 1" clearance required to combustible material from B-vent 2. Provide calc on combustion air into confined space 3. CO alarm outside upper bedrooms