

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497 Email: dcbuilding@douglas.co.us

> Permit Number: 23-00089 Inspection Number: 03781608

Building Inspection Report

Permit Information

Job Address: 9619 HUGGINS CT PARKER Job Type: Mechanical Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 02/06/2023 Inspection Time: 11:23 AM Inspection Type: Final Electric Inspection Code: 42 Outcome: Disapproved Inspected By: Justin Lett Charge Reinspection Fee: No

Comments

1. Connector required at end of FMC in ceiling that contains NM cable 2. Max OCPD for A/C 40A per nameplate-currently 50A installed