



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-06545
Inspection Number: 03788037

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 253 STONE POINTE TRL CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 03/03/2023
Inspection Time: 1:21 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

1. NP-garage east wall
 2. Secure 14/2 at can light-laundry room-south can
 3. Add outlet-dining room at window wall
 4. Master bedroom fireplace wiring incomplete
 5. Outlets required within 6 ft of both master bedroom exterior doors
 6. Fan wiring incomplete at master bedroom closet/ laundry
 7. Outlet at doorway in master closet/ laundry required on 29A circuit
 8. Move outlets to stud face in NE bedroom walls
 9. Add outlet-right of doorway in NE bedroom
 10. Additional support required at 14/2 cable above closet in NE bedroom
- inspection terminated at main level-2nd floor and basement not inspected