

Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-08646
Inspection Number: 03788110

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 1050 VINTAGE PL CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/03/2023
Inspection Time: 3:55 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

1. Outlet in 2nd bedroom bathroom upstairs required to be on 20A circuit
2. Bedroom 3 circuit potentially overloaded-max 10 openings on 15A circuit
3. Outlet required within 6 ft of wall break in study-east wall
4. Bond sconce boxes at either side of fireplace in office
5. Secure fireplace cable within 12" of cable entry in office
6. Staple NM cables flat above ceiling at office entry
7. Secure NM cable in laundry room-washer outlet