



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-06545
Inspection Number: 03788463

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 253 STONE POINTE TRL CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 03/06/2023
Inspection Time: 11:18 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

1. Master bedroom laundry outlet at doorway required to be on 20A circuit
2. Secure light box at stair landing-1st to second floor
3. Add outlet in dining area at window wall
4. Master bedroom laundry fan not wired
5. Bond basement stair light switch box-bottom of stairs
6. Move outlet box to front of studs-NW basement bedroom bathroom
7. NP-basement bar at window
8. Incomplete wiring at basement fireplace-12/2 cable coiled up at right side
9. Secure can lights in basement gym area
10. Outlet boxes missing at master bedroom-each side of doors
11. Outlet box missing at guest bedroom right of doorway