



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 23-01258  
Inspection Number: 03789632

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 8879 TAPPY TOORIE CIR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 03/10/2023  
**Inspection Time:** 5:17 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Disapproved  
**Inspected By:** Matt Mazzara  
**Charge Reinspection Fee:** No

### Comments

- 1)ENT must secure to box by fitting, floor heat
  - 2)cord for tub not permitted concealed in floor, req raceway
  - 3)bidet recep not permitted within 3' of tub rim
  - 4)tape/mud jbox garage ceiling, living space above
- Note:per Doug Co amendments max 10 openings 15amp circuits and 12 openings 20amp circuits