



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-01258
Inspection Number: 03789634

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8879 TAPPY TOORIE CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/09/2023
Inspection Time: 12:58 PM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release: No
Provider:
Outcome: Approved
Inspected By: Brian Schroder
Charge Reinspection Fee: No

Comments

NA