



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 23-01258  
Inspection Number: 03790340

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 8879 TAPPY TOORIE CIR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 03/13/2023  
**Inspection Time:** 2:19 PM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Approved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

\*\* patch behind j-box on garage ceiling, will check at final \*\*