Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-01292
Inspection Number: 03790349

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 3093 BELAY PT CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/13/2023
Inspection Time: 9:56 AM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Approved
Inspected By: Brian Schroder
Charge Reinspection Fee: No