



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317
Inspection Number: 03792147

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 03/20/2023
Inspection Time: 10:11 AM
Inspection Type: Roof Truss
Inspection Code: 127
Outcome: Disapproved
Inspected By: Rick Chadwick
Charge Reinspection Fee: No

Comments

1. FJ1 and FJ2 need to provide bearing and truss clips 2. Truss clips at garage bearing wall E3 and E4 trusses