

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497 Email: dcbuilding@douglas.co.us

> Permit Number: 22-06506 Inspection Number: 03794625

Building Inspection Report

Code Reviewed Under: 2018 IBC

Permit Information

Job Address: 12185B DUMONT WAY LITTLETON Job Type: Building Description: CM - Cell Site Scope of Work: Alteration

Inspection Details

Inspection Date: 03/29/2023 Inspection Time: 10:13 AM Inspection Type: Final Electric Inspection Code: 42 Outcome: Disapproved Inspected By: Henry VanSchaack Charge Reinspection Fee: No

Comments

Working clearance required in front of PPC per 110.26
bushings required on conduits enclosing #4 and larger conductors in HPL3 cabinet per 300.4