



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-06506  
Inspection Number: 03794626

## Building Inspection Report

Code Reviewed Under: 2018 IBC

### Permit Information

**Job Address:** 12185B DUMONT WAY LITTLETON  
**Job Type:** Building  
**Description:** CM - Cell Site  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 03/29/2023  
**Inspection Time:** 10:14 AM  
**Inspection Type:** Final Building  
**Inspection Code:** 108  
**Outcome:** Disapproved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

Provide 3rd party documentation for structural attachment of antennas to tower