



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-01292
Inspection Number: 03802185

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 3093 BELAY PT CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/26/2023
Inspection Time: 10:12 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Approved
Inspected By: Brian Schroder
Charge Reinspection Fee: No