



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03803652

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 05/02/2023

Inspection Time: 9:38 AM

Inspection Type: Weather Resistive Barrier

Inspection Code: 132

Outcome: Disapproved

Inspected By: Rick Chadwick

Charge Reinspection Fee: No

### Comments

1. Install all quick flashing correctly 2. Seal all penetrations 3. Install counter flashing at deck 4. Close openings with osb and tape joints at missing windows 5. Flashing at front entry