



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 23-02343  
Inspection Number: 03803901

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 10905 S EAST CHERRY CREEK RD ELBERT  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 05/04/2023  
**Inspection Time:** 10:12 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Approved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Island only modification. Exterior walls left as is with new devices only.

1. Need 3 recepts to cover island counter square footage requirement 2. Add recep to cover wall space of island per 210.52-can be fed from island recep circuit as long as that circuit does not have more than 4 recepts per DC amendment to NEC-will verify at final

Notes for final-TR recep at micro, AFCI/GFCI protection per 210.12/210.8/406.4, DW cord need grommet

Note-smoke alarms required in each bedroom, adjacent to each bedroom, every level. All require commercial power, battery back up, fully interconnected