



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-02343
Inspection Number: 03803901

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 10905 S EAST CHERRY CREEK RD ELBERT
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/04/2023
Inspection Time: 10:12 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

Island only modification. Exterior walls left as is with new devices only.

1. Need 3 recepts to cover island counter square footage requirement 2. Add recep to cover wall space of island per 210.52-can be fed from island recep circuit as long as that circuit does not have more than 4 recepts per DC amendment to NEC-will verify at final

Notes for final-TR recep at micro, AFCI/GFCI protection per 210.12/210.8/406.4, DW cord need grommet

Note-smoke alarms required in each bedroom, adjacent to each bedroom, every level. All require commercial power, battery back up, fully interconnected