



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-01258
Inspection Number: 03807821

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8879 TAPPY TOORIE CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/19/2023
Inspection Time: 4:59 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Jonathan Pastore
Charge Reinspection Fee: No

Comments

1. Pendant fixture shall not be installed above bathrub
2. Provide UL listing of bathtub
3. Provide UL listing for illuminated mirrors
(Mirror case bonded?)