



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 23-01258  
Inspection Number: 03807821

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 8879 TAPPY TOORIE CIR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 05/19/2023  
**Inspection Time:** 4:59 PM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Jonathan Pastore  
**Charge Reinspection Fee:** No

### Comments

1. Pendant fixture shall not be installed above bathrub
2. Provide UL listing of bathtub
3. Provide UL listing for illuminated mirrors  
(Mirror case bonded?)