



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-01258
Inspection Number: 03807822

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8879 TAPPY TOORIE CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/19/2023
Inspection Time: 10:43 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Robert Stratton
Charge Reinspection Fee: No

Comments

No answer at doorbell or knock several times