



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 23-02343  
Inspection Number: 03811641

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 10905 S EAST CHERRY CREEK RD ELBERT  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 06/07/2023  
**Inspection Time:** 10:09 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

1. TR recepts required at island per 406.12 2. GFCI protection required at center recep of island 3. All recepts in island require AFCI protection per 210.12 4. Receptacles that serve counter cannot be under overhang greater than 6" 5. Provide crawler access to check jboxes 6. Label all circuits effected by island change at panels 7. Micro recep requires AFCI/GFCI-210.12/210.8. 8. Grommet at DW cord—see notes that were left at rough electric

Note-smokes/CO ok.