



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-02343
Inspection Number: 03811641

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 10905 S EAST CHERRY CREEK RD ELBERT
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/07/2023
Inspection Time: 10:09 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

1. TR recepts required at island per 406.12 2. GFCI protection required at center recep of island 3. All recepts in island require AFCI protection per 210.12 4. Receptacles that serve counter cannot be under overhang greater than 6" 5. Provide crawler access to check jboxes 6. Label all circuits effected by island change at panels 7. Micro recep requires AFCI/GFCI-210.12/210.8. 8. Grommet at DW cord—see notes that were left at rough electric

Note-smokes/CO ok.