



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-02343
Inspection Number: 03811642

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 10905 S EAST CHERRY CREEK RD ELBERT
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/07/2023
Inspection Time: 3:37 PM
Inspection Type: Rough HVAC
Inspection Code: 27
Outcome: Approved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No