



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-03374

Inspection Number: 03812679

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 400 N RUSSELLVILLE RD FRANKTOWN

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 06/09/2023

Inspection Time: 10:20 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

Smoke alarms required in each lower bedroom, main floor and upper loft. All require commercial power, battery backup, interconnected. Interconnection can be wireless-battery only not permitted