



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-04680
Inspection Number: 03814207

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2701 CASTLE PINES DR NORTH CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/16/2023
Inspection Time: 12:00 PM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Approved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

Parallel 4/0, 2/0 neutral, #2 ground 75 ft from pedestal to house, 24"+ deep with warning ribbon