



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03814245

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 06/16/2023

Inspection Time: 10:26 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

Corrections incomplete from previous—6. Fan rated box at nook-314.27 11. Submit revisions for second kitchen at lower level