



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03814720

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 06/20/2023

Inspection Time: 10:21 AM

Inspection Type: Interior Gas Line

Inspection Code: 30

Meter Release:

Provider: Black Hills Energy

Outcome: Disapproved

Inspected By: Rick Chadwick

Charge Reinspection Fee: No

Comments

10 lb test on 30 lb gauge