



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03815400

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 06/22/2023

Inspection Time: 10:07 AM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Disapproved

Inspected By: Rick Chadwick

Charge Reinspection Fee: No

### Comments

1. DWV lost test upper level laundry 2. Nail plates basement laundry and kitchen 3. Backfill or level master lav  
4. Stud shoes at overbores OK TO INSULATE PER ELECTRICAL