



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-02559  
Inspection Number: 03815616

## Building Inspection Report

Code Reviewed Under: 2018 IBC

### Permit Information

**Job Address:** 565A FLINTWOOD RD FRANKTOWN  
**Job Type:** Building  
**Description:** CM - Cell Site  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 06/21/2023  
**Inspection Time:** 1:40 PM  
**Inspection Type:** Electric Service Equipment Partial  
**Inspection Code:** 91  
**Meter Release:** Yes  
**Provider:** CORE  
**Outcome:** Approved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Items not corrected from previous. 1. NEW ITEM-Provide barriers at supply side terminations in disconnect-forgot to note this at last inspection 2. Provide accurate fault current value-per CORE, fault current at transformer is 6944 3. Arc flash labels required 5. Signs required per 702.7(A), (B), (C)-can do these signs at final.

Ok for meter release and can check items at next inspection.