



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03816362

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 06/28/2023

Inspection Time: 1:12 PM

Inspection Type: Insulation Thermal

Inspection Code: 36

Outcome: Cancelled

Inspected By: Fredrick Mooney

Charge Reinspection Fee: No

Comments

Duplicate