



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-03374

Inspection Number: 03816500

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 400 N RUSSELLVILLE RD FRANKTOWN

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 06/27/2023

Inspection Time: 1:39 PM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Disapproved

Inspected By: Fredrick Mooney

Charge Reinspection Fee: No

Comments

Stud shoes still missing under kitchen sink.

Ok to insulate.

Recall rough with insulation.