



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-03374
Inspection Number: 03816501

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 400 N RUSSELLVILLE RD FRANKTOWN
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/27/2023
Inspection Time: 1:40 PM
Inspection Type: Rough Plumbing
Inspection Code: 28
Outcome: Disapproved
Inspected By: Fredrick Mooney
Charge Reinspection Fee: No

Comments

See rough.