



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 23-02343  
Inspection Number: 03818247

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 10905 S EAST CHERRY CREEK RD ELBERT  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 07/06/2023  
**Inspection Time:** 10:14 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Correction not completed from previous inspection—3. All recepts in island require AFCI protection per 210.12-DW & Disposal circuits still require AFCI protection per 210.12/406.4(D)