



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-04680
Inspection Number: 03818364

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2701 CASTLE PINES DR NORTH CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/06/2023
Inspection Time: 12:10 PM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release:
Provider: CORE
Outcome: Disapproved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

Line side terminations at exterior disconnects incomplete-not ready for service inspection