



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-02343
Inspection Number: 03819718

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 10905 S EAST CHERRY CREEK RD ELBERT
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/12/2023
Inspection Time: 10:57 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

No access—DC employees are not allowed to enter occupied residence without adult present.