



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-04680
Inspection Number: 03821902

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2701 CASTLE PINES DR NORTH CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/20/2023
Inspection Time: 10:47 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Jeremy Bock
Charge Reinspection Fee: No

Comments

1. 2 outlets missing at kitchen island
 2. Grommet required at dishwasher cord cabinet penetration-check both
 3. GFCI protection required at kitchen countertop outlet-right of window
 4. Update panel labeling-all panels
- check arc fault protection at next inspection