



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 22-04680  
Inspection Number: 03823861

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 2701 CASTLE PINES DR NORTH CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 07/28/2023  
**Inspection Time:** 3:45 PM  
**Inspection Type:** Final Building  
**Inspection Code:** 108  
**Outcome:** Disapproved  
**Inspected By:** Fredrick Mooney  
**Charge Reinspection Fee:** No

### Comments

1. Add water hammer arrestors at all dishwashers.
2. Handrails need to be graspable.  
R311.7.8.5 section 2.
3. Pipe t&P valve to floor drain at mech room.