



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 21-06545  
Inspection Number: 03823863

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 253 STONE POINTE TRL CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 07/31/2023  
**Inspection Time:** 11:55 AM  
**Inspection Type:** Final Defensible Space  
**Inspection Code:** 61  
**Outcome:** Disapproved  
**Inspected By:** Jill Welle  
**Charge Reinspection Fee:** No

### Comments

Thin oak clump in back corner to remove dead, remove small stems to achieve a 3 ft to 5 ft stem spacing and prune to remove contact with surface fuels. End on slope drop off.