



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 21-06545  
Inspection Number: 03823864

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 253 STONE POINTE TRL CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 07/31/2023  
**Inspection Time:** 5:53 AM  
**Inspection Type:** Final Driveway  
**Inspection Code:** 43  
**Outcome:** Approved  
**Inspected By:** June Amicucci  
**Charge Reinspection Fee:** No

### Comments

No issues found for final driveway inspection