



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-06506
Inspection Number: 03824387

Building Inspection Report

Code Reviewed Under: 2018 IBC

Permit Information

Job Address: 12185B DUMONT WAY LITTLETON
Job Type: Building
Description: CM - Cell Site
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/31/2023
Inspection Time: 10:46 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

Corrections not done

** 30" wide, 36" deep, from ground to 6'-6" above ground in front of transfer panel **