



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-02559
Inspection Number: 03824969

Building Inspection Report

Code Reviewed Under: 2018 IBC

Permit Information

Job Address: 565A FLINTWOOD RD FRANKTOWN
Job Type: Building
Description: CM - Cell Site
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/03/2023
Inspection Time: 10:55 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

Correct fault current value-noted value exceeds what current utility transformer would produce-CORRECT
AND PROCEED