



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-05226
Inspection Number: 03827627

Building Inspection Report

Permit Information

Job Address: 15375 GREENSTONE CIR PARKER
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 08/11/2023
Inspection Time: 9:54 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Jon Dickey
Charge Reinspection Fee: No

Comments

Seal nails at air vent west side. Seal hole at bottom of valley upper east side. Missing bird stop flashing northeast side. Inspected by Greg