



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-01517
Inspection Number: 03828238

Building Inspection Report

Code Reviewed Under: 2018 IBC

Permit Information

Job Address: 5453 PETERSON RD SEDALIA
Job Type: Building
Description: CM - Cell Site
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/16/2023
Inspection Time: 3:37 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No